



NOTES:

1. WHERE AIR RELIEF VALVES (ARVs) ARE IDENTIFIED ON THE PLANS AS TEMPORARY, TRACER WIRE IS NOT REQUIRED AND ALL MATERIALS CAN BE SALVAGED AFTER THE CORP IS CLOSED, THE LINE IS CAPPED WITH A BRASS CAP AND FITTINGS ARE WRAPPED IN 10-MIL TAPE..



Engineering Division

Manual Air Relief Detail

*Logan McInnis*

Approved By  
Utilities Engineer  
Logan McInnis, PE

Revised: 09/28/2020

STD - 410