



GENERAL NOTES

1. WET WELL SECTIONS SHALL BE PRECAST CONCRETE MEETING ASTM C478
2. WET WELL SHALL HAVE PREFORMED FLEXIBLE SEALANT JOINTS MEETING ASTM C990. CONTRACTOR SHALL INSTALL EXTERNAL JOINT WRAP ON ALL WET WELL JOINTS PRIOR TO APPLYING EXTERNAL COATING. EXTERNAL JOINT WRAP SHALL BE UPPER PENINSULA RUBBER COMPANY (CADILLOC). CONSEAL (CS-212) ON APPROVAL EQUAL.
3. CONTRACTOR SHALL APPLY AN EXTERNAL WATERPROOF COATING (MINIMUM 60 MILS) TO WET WELL AS PER THE CITY PUBLIC WORKS MANUAL REQUIREMENTS.
4. CONTRACTOR SHALL APPLY A LINER (MINIMUM 125 MILS) TO THE INTERIOR OF WET WELL AS PER THE CITY PUBLIC WORKS MANUAL REQUIREMENTS.
5. ALL EXPOSED DUCTILE IRON PIPE AND FITTINGS SHALL BE BE MANUFACTURED AND DELIVERED WITH NO ASPHALTIC COATING. EXPOSED PIPE AND FITTINGS SHALL BE COATED OUTSIDE WITH A FACTORY-APPLIED, HIGH-SOLIDS EPOXY PRIMER WITH ALL EXPOSED PIPES, VALVES AND FITTINGS FIELD COATED AFTER ASSEMBLY WITH A POLYAMIDE EPOXY COATING OF 10 MILS MINIMUM THICKNESS.
6. ALL PUMP AND PIPE SIZING TO BE COMPLETE BY ENGINEER. DISCHARGE PIPING 4" MINIMUM



Engineering Division

Standard Sewer Lift Station

(Sheet 1 of 3)

Ross Mollenhauer

Approved By Utility
Project Manager -
Ross Mollenhauer, PE

Adopted: 9/28/2020

STD - 550