



**GENERAL NOTES:**

1. MAXIMUM LINE DEPTH IS 13'. DEVIATIONS MAY BE ALLOWED BY CITY ENGINEERING.
2. CONNECTIONS TO EXISTING SEWER MAINS SHALL BE TAPPED AT THE CONTRACTORS EXPENSE, AND PREDCO FAST FIT SADDLES OR APPROVED EQUAL SHALL BE USED. WHEN THE SEWER MAIN AND SEWER SERVICE LATERALS ARE INSTALLED UNDER ONE CONTRACT, IN-LINE TEES ONLY SHALL BE PROVIDED FOR THE SERVICE LATERALS. TEES SHALL BE ROLLED TO A 45 DEGREE ANGLE.
3. AN EXCAVATION PERMIT IS REQUIRED FOR EACH STUB.
4. SEWER SERVICE STUBS SHALL BE INSTALLED WHERE SHOWN ON THE DRAWINGS OR AS SPECIFIED BY CITY ENGINEERING.
5. IN ORDER TO KEEP SERVICE LINES DEEP ENOUGH TO SERVE EACH HOME AND PASS UNDER WATER MAINS, A 22 DEGREE FITTING MAY BE ALLOWED BY THE CITY ENGINEER AT THE SEWER MAIN TAP.
6. ALL COMMERCIAL SERVICE STUBS SHALL BE 6" MINIMUM DIAMETER.
7. ALL SINGLE DWELLING UNIT SERVICE STUBS SHALL BE 4" MINIMUM DIAMETER.



Engineering Division

**Standard Sewer Service Stub**

Approved By Utility  
Project Manager –  
Ross Mollenhauer, PE

Revised: 09/28/2020

**STD - 520**