



GENERAL NOTES:

1. PIPE MATERIAL SHALL BE HDPE OR SDR35
2. DRAIN PIPE SHALL BE 4" MINIMUM DIAMETER
3. FILTER FABRIC AND WATER PROOF FABRIC IS REQUIRED, BEFORE PLACING WASHED ROCK AND BACKFILLING



Engineering Division

Footing Drain System

Approved By
Utility Engineer
Andy Schultz, PE

Revised: 09/28/2020

STD - 632