



KEYED NOTES:

1. MINIMUM OF FOUR (4") INCHES OF CONCRETE SIDEWALK (TYPICAL), MINIMUM SIX (6") INCHES CONCRETE SIDEWALK THROUGH RESIDENTIAL DRIVEWAY OR MINIMUM EIGHT (8") INCHES CONCRETE SIDEWALK THROUGH COMMERCIAL DRIVEWAY OR ON ADA RAMPS PER STD DWGS.
2. MINIMUM OF FOUR (4") INCHES OF BASE SHALL BE COMPACTED TO 95% PROCTOR DENSITY.
3. MINIMUM OF SIX (6") INCHES OF SUB GRADE SHALL BE COMPACTED TO 95% PROCTOR DENSITY.
4. CITY ENGINEER MAY REQUIRE ADDITIONAL BASE, DEPENDING ON SUB GRADE MATERIAL.
5. CONTRACTION JOINTS SHALL FORM AS NEAR A SQUARE PANEL AS POSSIBLE, NO SINGLE PANEL SHALL EXCEED TEN (10') FEET ON ANY SIDE. LONGITUDINAL JOINTS REQUIRED IF SIDEWALK WIDTH EXCEEDS TEN (10') FEET.
6. CONTRACTION JOINTS SHALL BE ONE-FOURTH (1/4) THE CONCRETE THICKNESS OR A MINIMUM OF ONE (1") INCH DEEP.
7. EXPANSION JOINTS OF ONE-HALF (1/2") INCH THICK MASTIC MATERIAL SHALL BE PLACED AT THE FOLLOWING LOCATIONS:
 - 7.1. EVERY FIFTY (50') FEET OF UNINTERRUPTED SIDEWALK.
 - 7.2. P.C.S AND P.T.S OF CURVES.
 - 7.3. GRADE BREAKS.
 - 7.4. RESIDENTIAL DRIVEWAYS SIX (6") INCH DEEP MASTIC SHALL BE INSTALLED AT THE TOP OF THE TRANSITION ON BOTH SIDES AND SHALL BE PINNED IN PLACE BEFORE POURING.
 - 7.5. COMMERCIAL DRIVEWAYS EIGHT (8") INCH DEEP MASTIC SHALL BE INSTALLED AT THE TOP OF THE TRANSITION ON BOTH SIDES AND SHALL BE PINNED IN PLACE BEFORE POURING.
 - 7.6. AT OTHER LOCATIONS AS SPECIFIED BY CITY ENGINEERING DIVISION.
 - 7.7. ALL EXPANSION JOINTS SHALL BE PLACED FLUSH OR JUST BELOW TOP FINISHED SURFACE OF SIDEWALK.
 - 7.8. ALL EXPANSION JOINTS SHALL BE FULL DEPTH, FULL WIDTH AND SECURED IN PLACE BEFORE THE FORMS WILL BE APPROVED.
8. FINISHED SURFACE - 12" MINIMUM SHOULDER UNLESS OTHERWISE APPROVED BY CITY ENGINEER.
9. FINISHED SIDEWALK SURFACE SHALL HAVE MEDIUM-TO-HEAVY BROOM TEXTURE.
10. NO SIDEWALK SHALL BE POURED WITHOUT AN INSPECTION AND APPROVAL OF FORM PLACEMENT BY CITY ENGINEERING DIVISION.
11. CONSTRUCTION MATERIALS AND PROCEDURES SHALL CONFORM TO EXISTING CITY STANDARD SPECIFICATIONS FOR M-4000 CEMENT CONCRETE AND MONTANA PUBLIC WORKS STANDARD SPECIFICATIONS SECTIONS 02528 AND 03310.
12. CITY OF MISSOULA REQUIRES 564 LBS OF PORTLAND CEMENT PER CY OF CONCRETE.



Engineering Division

Typical Sidewalk Section

Approved By
 City Engineer
 Kevin J. Slovarp

Adopted: 02/29/1996
 Revised: 03/22/2017

STD - 752