

Per- and polyfluoroalkyl substances (PFAS) have No Federal Maximum Contaminant Level as of December 31, 2020

Laboratory Method Detection Level (MDL) for PFAS's are

Analytical Units ug/L (ppb) part per billion

PFOS	0.04	or	40 ppt parts per trillion (ng/L) nanograms/liter
PFOA	0.02		
PFBS	0.09		
PFNA	0.02		
PFHpA	0.01		
PFHxS	0.03		

State of Montana has the following Human Health Standards

Analytical Units ug/L (ppb)

PFOS	0.07	or	70 ppt parts per trillion (ng/L) nanograms/liter
PFOA	0.07		

OUR WATER WAS SAMPLED IN MAY 2013 AND NOVEMBER 2013

Well 12 TP (Judi Dr.)

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

Well 38 TP (23rd St. East)

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

Well 22 TP (Intermountain)

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

Well 30 TP (Bank St.)

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

Well 9 TP (Dixon Ave.)

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

Well 19 TP (N. Russel)

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

Well 25 TP (Stephens Ave.)

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND

Well 13 TP (Mountain View)

PFOS	ND
PFOA	ND
PFBS	ND
PFNA	ND
PFHpA	ND
PFHxS	ND