



For SI: 1 foot = 304.8 mm.

Figure 503.1.1(2)
FIRE DEPARTMENT ACCESS ON TWO SIDES

NOTES:

A long, narrow building may require fire department access roads on two sides only, if all portions of the exterior of the grade level story are within 150 feet of the access road.



Standard Detail (STD) Fire Department Access On Two Sides Figure IFC 503.1.1(2)

| | |
|---|---|
| APPROVED BY DAX FRASER, FIRE MARSHAL MFD FIRE PREVENTION BUREAU | SCALE: N.T.S. DATE: 05/19/2021 FIGURE BY: ICC |
|---|---|

STD - 503.1.1(2)