



NOTES:

Table D105.3 Proximity to building. Aerial fire apparatus access roads shall be located not less than 15 feet and not greater than 30 feet from building, and shall be positioned parallel to one entire side of the building.



Standard Detail (STD) Aerial Fire Apparatus Access Road For Buildings Greater Than 30 Feet In Height Figure D105.3

APPROVED BY
DAX FRASER, FIRE MARSHAL
MFD FIRE PREVENTION BUREAU

SCALE: N.T.S.
DATE: 12/15/2022
FIGURE & TABLE BY: ICC

STD - D105.3