



NOTES:

Small buildings may require an access road on one side only, if the access road is within 150 feet of all portions of the grade level floor.



Standard Detail (STD) Small Building Access Figure IFC 503.1.1(3)

APPROVED BY
DAX FRASER, FIRE MARSHAL
MFD FIRE PREVENTION BUREAU

SCALE: N.T.S.
DATE: 05/19/2021
FIGURE BY: ICC

STD - 503.1.1(3)